

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 23

Dated: 08/04/2025

It is certified that an inspection team headed by Priyanka Raikwal (E.O)

(Name of Officers with designation) from Nagar Panchayat Nanakmatta

(Name of Department/ Office) inspected the SHRI GURU NANAK ACADEMY NANAKMATT

(Name & Address of the school) on 08/04/2025 (date of inspection) and found that the SHRI GURU NANAK ACADEMY (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 Year

Signature with Seal: 

Name : Priyanka Raikwal

Designation : Executive Officer


Name & Address of the Office / Department : अधिशासी अधिकारी
नगर पंचायत नानकमत्ता
रुधम सिंह नगर

To

SHRI GURU NANAK ACADEMY
NANAKMATT SAHIB (U.S. NAGAR) UK - 262311

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


Manager
Shri Guru Nanak Academy
Senior Secondary School
Nanakmatta Sahib (U.S. Nagar)
Uttarakhand


PRINCIPAL
Shri Guru Nanak Academy
Nanakmatta Sahib
U.S. Nagar (Uttarakhand)



**District Level Water Quality Testing and Monitoring
Laboratory Uttarakhand Jal Sansthan, Collectrate
Campus, Rudrapur (U.S.Nagar)**

TC-13345

TEST REPORT

Name and Address of Organization/ Customer	Shri Guru Nanak Academy Residential School, Nanakmatta, Khatima, U.S.Nagar (Uttarakhand)		
Test Report ID	07/UJS/DLWQTML/2024-25	Reporting Date	26/03/2025
UJR No.	TC1334524000000071	Sample Location	Sample-01, Submerisible
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/SGA-01		
Date of Start of Analysis:	15/03/2025		
Date of End of Analysis:	15/03/2025		
Date and Time of Sample Received:	15/03/2025 & 4:15 pm		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 19500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022.	7.21	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	270	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.91	1	5
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	IS 3025 (Part 23), 2023	141	200	600
5.	Total Hardness (as CaCO ₃), mg/L, Max	IS 3025 (Part 21), 2009	174	200	1000
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	45.6	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	12.98	250	1000
8.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	14.58	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	Less than 5	5	15
10.	Odour	IS 3025 (Part 5): 2018	Agreeable	Agreeable	Agreeable

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Manager

**Shri Guru Nanak Academy
Senior Secondary School
Nanakmatta Sahib (U.S.Nagar)
Uttarakhand**

PRINCIPAL

**Shri Guru Nanak Academy
Nanakmatta Sahib
U.S.Nagar (Uttarakhand)**

Review and Authorized By

**(E. Mukesh Kumar)
Technical Manager, Lab**

**Shri Guru Nanak Academy
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S.Nagar**